



Minnesota Pollution
Control Agency

520 Lafayette Road North
St. Paul, MN 55155-4194

Existing Subs

Compliance Inspection Form



061114522

061013000
1114 523 524

Inspection results based on Minnesota Pollution Control Agency (MPCA) requirements and attached forms – additional local requirements may also apply.

Submit completed form to Local Unit of Government (LUG) and system owner within 15 days

For local tracking purposes:



System Status

System status on date (mm/dd/yyyy): 7/31/2019

☒ **Compliant – Certificate of Compliance**
(Valid for 3 years from report date, unless shorter time frame outlined in Local Ordinance.)

☐ **Noncompliant – Notice of Noncompliance**
(See Upgrade Requirements on page 3.)

Reason(s) for noncompliance (check all applicable)

- ☐ Impact on Public Health (Compliance Component #1) – Imminent threat to public health and safety
- ☐ Other Compliance Conditions (Compliance Component #3) – Imminent threat to public health and safety
- ☐ Tank Integrity (Compliance Component #2) – Failing to protect groundwater
- ☐ Other Compliance Conditions (Compliance Component #3) – Failing to protect groundwater
- ☐ Soil Separation (Compliance Component #4) – Failing to protect groundwater
- ☐ Operating permit/monitoring plan requirements (Compliance Component #5) – Noncompliant

Property Information

Parcel ID# or Sec/Twp/Range: 061013000

06114522 + 061114523

Property address: 13512 Maple Rd. Lake Park, MN 56554

Reason for inspection: County Request

Property owner: Dale Torgerson ET AL

Owner's phone:

or

Owner's representative:


Representative phone:

Local regulatory authority: Becker County

Regulatory authority phone: 218-846-7314

Brief system description: 1000 gal. tank to 330 gal lift tank to 500 sq.ft. drainfield.

Comments or recommendations:



Certification

I hereby certify that all the necessary information has been gathered to determine the compliance status of this system. No determination of future system performance has been nor can be made due to unknown conditions during system construction, possible abuse of the system, inadequate maintenance, or future water usage.

Inspector name: Phil Stoll

Certification number: 7526

Business name: Stoll Inspections

License number: 2982

Inspector signature: *Phil Stoll*

Phone number: 218-839-1849

Necessary or Locally Required Attachments

- ☒ Soil boring logs
- ☐ System/As-built drawing
- ☒ Forms per local ordinance
- ☐ Other information (list):

1. Impact on Public Health – Compliance component #1 of 5**Compliance criteria:**

System discharges sewage to the ground surface.

☐ Yes ☒ No

System discharges sewage to drain tile or surface waters.

☐ Yes ☒ No

System causes sewage backup into dwelling or establishment.

☐ Yes ☒ No**Any "yes" answer above indicates the system is an imminent threat to public health and safety.**

Comments/Explanation:

Verification method(s):☒ Searched for surface outlet☒ Searched for seeping in yard/backup in home☐ Excessive ponding in soil system/D-boxes☐ Homeowner testimony (See Comments/Explanation)☐ "Black soil" above soil dispersal system☐ System requires "emergency" pumping☐ Performed dye test☐ Unable to verify (See Comments/Explanation)☐ Other methods not listed (See Comments/Explanation)**2. Tank Integrity – Compliance component #2 of 5****Compliance criteria:**

System consists of a seepage pit, cesspool, drywell, or leaching pit.

☐ Yes ☒ No*Seepage pits meeting 7080.2550 may be compliant if allowed in local ordinance.*

Sewage tank(s) leak below their designed operating depth.

☐ Yes ☒ No

If yes, which sewage tank(s) leaks:

Any "yes" answer above indicates the system is failing to protect groundwater.

Comments/Explanation:

Verification method(s):☒ Probed tank(s) bottom☒ Examined construction records☐ Examined Tank Integrity Form (Attach)☐ Observed liquid level below operating depth☐ Examined empty (pumped) tanks(s)☐ Probed outside tank(s) for "black soil"☐ Unable to verify (See Comments/Explanation)☐ Other methods not listed (See Comments/Explanation)**3. Other Compliance Conditions – Compliance component #3 of 5**a. Maintenance hole covers are damaged, cracked, unsecured, or appear to be structurally unsound. ☐ Yes* ☒ No ☐ Unknownb. Other issues (electrical hazards, etc.) to immediately and adversely impact public health or safety. ☐ Yes* ☒ No ☐ Unknown***System is an imminent threat to public health and safety.**

Explain:

c. System is non-protective of ground water for other conditions as determined by inspector. ☐ Yes* ☒ No***System is failing to protect groundwater.**

Explain:

4. Soil Separation – Compliance component #4 of 5

Date of installation: _____

☒ Unknown

(mm/dd/yyyy)

Shoreland/Wellhead protection/Food beverage lodging?

☒ Yes ☐ No**Compliance criteria:**

For systems built prior to April 1, 1996, and not located in Shoreland or Wellhead Protection Area or not serving a food, beverage or lodging establishment:

☐ Yes ☐ No

Drainfield has at least a two-foot vertical separation distance from periodically saturated soil or bedrock.

Non-performance systems built April 1, 1996, or later or for non-performance systems located in Shoreland or Wellhead Protection Areas or serving a food, beverage, or lodging establishment:

☒ Yes ☐ No

Drainfield has a three-foot vertical separation distance from periodically saturated soil or bedrock.*


"Experimental", "Other", or "Performance" systems built under pre-2008 Rules; Type IV or V systems built under 2008 Rules (7080, 2350 or 7080.2400 (Advanced Inspector License required)

☐ Yes ☐ No

Drainfield meets the designed vertical separation distance from periodically saturated soil or bedrock.

Verification method(s):

Soil observation does not expire. Previous soil observations by two independent parties are sufficient, unless site conditions have been altered or local requirements differ.

☒ Conducted soil observation(s) (Attach boring logs)☐ Two previous verifications (Attach boring logs)☐ Not applicable (Holding tank(s), no drainfield)☐ Unable to verify (See Comments/Explanation)☐ Other (See Comments/Explanation)**Comments/Explanation:****Indicate depths or elevations**

A. Bottom of distribution media	30"
B. Periodically saturated soil/bedrock	>66"
C. System separation	>36"
D. Required compliance separation*	36"

*May be reduced up to 15 percent if allowed by Local Ordinance.

Any "no" answer above indicates the system is failing to protect groundwater.**5. Operating Permit and Nitrogen BMP* – Compliance component #5 of 5** ☒ Not applicableIs the system operated under an Operating Permit? ☐ Yes ☐ No If "yes", A below is requiredIs the system required to employ a Nitrogen BMP? ☐ Yes ☐ No If "yes", B below is required

BMP = Best Management Practice(s) specified in the system design

If the answer to both questions is "no", this section does not need to be completed.**Compliance criteria**

a. Operating Permit number: _____

Have the Operating Permit requirements been met?

☐ Yes ☐ No

b. Is the required nitrogen BMP in place and properly functioning?


☐ Yes ☐ No**Any "no" answer indicates Noncompliance.**

Upgrade Requirements (Minn. Stat. § 115.55) An imminent threat to public health and safety (ITPHS) must be upgraded, replaced, or its use discontinued within ten months of receipt of this notice or within a shorter period if required by local ordinance. If the system is failing to protect ground water, the system must be upgraded, replaced, or its use discontinued within the time required by local ordinance. If an existing system is not failing as defined in law, and has at least two feet of design soil separation, then the system need not be upgraded, repaired, replaced, or its use discontinued, notwithstanding any local ordinance that is more strict. This provision does not apply to systems in shoreland areas, Wellhead Protection Areas, or those used in connection with food, beverage, and lodging establishments as defined in law.

Parcel Number: 061013000
Date & Initial: 7/31/19 PJS

System Drawing

The system drawing which includes and identifies a graphic scale in feet or indicates all setback distances, all septic/holding/lift tanks, drainfields, wells within 100 feet of system (indicate depth of wells), dwelling and non-dwelling structures, lot lines, road right-of-ways, easements, OHWLs, wetlands, and topographic features (i.e. bluffs).



Additional Comments: Septic in Compliance

