



100386000

12-1004136

**CERTIFICATE OF COMPLIANCE**  
**SEWAGE SYSTEM**

This certificate has been issued this 12 day of AUGUST 19 80

to certify compliance with regulations of Zoning Ordinance, Becker County, Minnesota.

The premises covered by this certificate are legally described as: E7/2NW1/4

Lake No. \_\_\_\_\_ Sec. 23 Twp. 139 Range 40 Twp. Name ERIE

New sewer system has 1000 gal. septic tank, 50 ft. from nearest well, 30 ft. from occupied building, over 10 ft. from property line, seepage bed is 375 sq. ft., 70 ft. from nearest well, 50 ft. from occupied building, 10 ft. from property line, and over 4 ft. from bottom to water table. 15 yds. rock.

Owner: Name JOHN LUNDER

STAR ROUTE

Address DETROIT LAKES, MN. 56501

Zip No. \_\_\_\_\_

Permit No. SP 12-10,043-29

Signed by: \_\_\_\_\_

*Floyd Swanby*

Zoning Administrator  
Becker County, Minnesota

White - Office  
 Yellow - Owner  
 Pink - Assessor  
 Goldenrod - Inspector

BECKER COUNTY ZONING ADMINISTRATION

Permit No. 10-004529  
 Date 8-11-80

COUNTY COURT HOUSE - Phone 218-847-3938 - Detroit Lakes, Minn. 56501

APPLICATION FOR BUILDING OR SEWAGE PERMIT AND CERTIFICATE OF OCCUPANCY

113

LEGAL DESCRIPTION AND LOCATION	80 AC. E 1/2 of NW 1/4						
	Lake No.	Lake Name	Lake Classif.	Sec.	TWP	Range	TWP Name
				23	139	46	ERIE

IDENTIFICATION: Please Print All Information

Owner	Last Name	First	Initial	Mailing Address - No. Street, City and State	Zip No.	Tel. No.
	LUNDER, John			STAR ROUTE DETROIT LAKES, MN		
Contractor	Name	Stanley Zobel				

TYPE OF IMPROVEMENT: <input type="checkbox"/> New Building <input type="checkbox"/> Alteration Other <u>sewer system</u>	RESIDENTIAL PROPOSED USE: <input checked="" type="checkbox"/> One Family Dwelling <input type="checkbox"/> Multiple Dwelling _____ Units	NON-RESIDENTIAL PROPOSED USE: Specify: _____ Size: _____
--	--	--

ESTIMATED COST OF IMPROVEMENT \$ _____ PRINCIPAL TYPE OF FRAME: <input type="checkbox"/> Masonry <input type="checkbox"/> Wood Frame <input type="checkbox"/> Structural Steel <input type="checkbox"/> Other - Specify _____ Type of Roof: _____	TYPE OF SEWAGE DISPOSAL: <input type="checkbox"/> Public <input checked="" type="checkbox"/> Individual Septic Tank, etc. WATER SUPPLY: <input type="checkbox"/> Public <input checked="" type="checkbox"/> Individual Well MECHANICAL EQUIPMENT: Elevator: <input type="checkbox"/> Yes <input type="checkbox"/> No Air Conditioning: <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Central <input type="checkbox"/> Unit	CONSTRUCTION STARTING DATE: _____ DIMENSIONS: Basement: <input type="checkbox"/> Yes <input type="checkbox"/> No Stories above basement: _____ Sq. feet (outside dimension) _____ Bedrooms <u>3</u> Baths <u>1</u> HEATING: <input type="checkbox"/> Electric <input type="checkbox"/> Gas <input type="checkbox"/> Oil <input type="checkbox"/> Coal <input type="checkbox"/> None Other: <u>Beef</u>
---	---	---

SEWAGE DISPOSAL SYSTEM DATA:	SEPTIC TANK	SEEPAGE PIT	DRAIN FIELD
Capacity	1000 Gls.	375 Sq. Ft.	Sq. Ft.
Distance from nearest well	50 Ft.	50 Ft.	Ft.
Distance from lake or stream	_____ Ft.	_____ Ft.	_____ Ft.
Distance from occupied building	10 Ft.	10 Ft.	Ft.
Distance from property line	10 Ft.	10 Ft.	Ft.
Distance from bottom to Water Table	_____ Ft.	4 Ft.	Ft.

All distances are shortest distance between nearest points

CHARACTERISTICS:

Lot Area is \_\_\_\_\_ square feet. Water frontage is N/A feet.

Building set back from high water mark is N/A feet. (Building Line)


Land height above high water mark at building line is \_\_\_\_\_ feet

Building set back from State highway is \_\_\_\_\_ feet - from road or street is \_\_\_\_\_ feet.

Side yard is +10 and +10 feet. Rear yard is \_\_\_\_\_ feet.

Building will be located +10 feet from septic tank (Sewage System Permit must be obtained before installation).

Building will be located +10 feet from soil absorption system (Cesspool, Drainfield, etc.).



Agreement: I hereby certify that the information contained herein is correct and agree to do the proposed work in accordance with the description above set forth and according to the provisions of the ordinances of Becker County, Minnesota. I further agree that any plans and specifications submitted herewith shall become a part of this permit application. I also understand that this permit is valid for a period of six (6) months. Applicant further agrees that no part of the sewage system shall be covered until it has been inspected and accepted. It shall be the responsibility of the applicant for the permit to notify the County Zoning Administrator, 48 hours before the job is ready for inspection.

Dated 8-11-80 Signature of Owner [Signature]

When signed and approved by the Zoning Administration this becomes your permit. Permission is hereby granted to the above named applicant to perform the work described in the above statement and/or as shown on the sketch. This permit is granted upon the express condition that the person to whom it is granted, and his agent, employees and workmen shall conform in all respects to the ordinances of Becker County, Minnesota. This permit may be revoked at any time upon violation of said ordinances.

MUST BE POSTED AT THE BUILDING SITE

Dated 8-11-80 [Signature]  
 Becker County Zoning Administrator

Permit Fee \$ 10.00 State Surcharge \$ 50

Comments: \_\_\_\_\_

**INSPECTOR'S CHECK LIST**  
*Make all measurements and computations*

	ACTUAL IS ↓	MINIMUM Shall Be ↓	Sq. Ft.
Building Set Back from High Water Mark	Ft.		Ft.
Building Set Back from State Highway	Ft.		Ft.
Side Yard	_____ & _____ Ft.	_____ & _____ Ft.	
Rear Yard	Ft.		Ft.
Elevation at Building Line above High Water Mark	Ft.		Ft.

**SEWAGE DISPOSAL SYSTEM STATISTICS**

*Bed*

CATEGORY	SEPTIC TANK				SEEPAGE PIT				DRAIN FIELD			
	Actual		Should be		Actual		Should be		Actual		Should be	
Capacity	<i>1000</i>	Gls.		Gls.	<i>375</i>	SF		SF		SF		SF
Distance from Nearest Well	<i>56</i>	F		F	<i>70</i>	F	<i>75</i>	F		F	<i>50</i>	F
Distance from Lake or Stream		F		F		F		F		F		F
Distance from Occupied Building	<i>30</i>	F	<i>10</i>	F	<i>56</i>	F	<i>20</i>	F		F	<i>20</i>	F
Distance from Property Line		F	<i>10</i>	F	<i>16</i>	F	<i>10</i>	F		F	<i>10</i>	F
Distance from Bottom to Water Table	<i>--</i>	F	<i>--</i>	F	<i>4</i>	F	<i>4</i>	F		F	<i>4</i>	F

Inspector's Comments: *Zohel Ansbali, General Sewer Soil, 15 yds Rock*

**INTERPRETATION OF ABBREVIATIONS**

- Gls — Gallons
- SF — Square Feet
- F — Linear Feet

*Mark Keeling*  
 Inspector's Signature

Inspection Dated *8-11* 19 *80*

\_\_\_\_\_  
 Title  
 \_\_\_\_\_  
 Agency