



260127000

SE 89

CERTIFICATE OF COMPLIANCE
SEWAGE SYSTEM

This certificate has been issued this 1 day of December 19 89.

to certify compliance with regulations of Zoning Ordinance, Becker County, Minnesota.

The premises covered by this certificate are legally described as: $\frac{1}{2}$ of NE $\frac{1}{4}$, 55 $\frac{1}{2}$, NW $\frac{1}{4}$ of 51 $\frac{1}{2}$ and 1 $\frac{1}{2}$ of SE $\frac{1}{4}$

Lake No.	Sec. <u>20</u>	Twp. <u>138</u>	Range <u>36</u>	Twp. Name <u>Rundberg</u>
CAPACITY	BLACK ROAD	SEPTIC TANK	500 SP	
DISTANCE FROM NEAREST WELL	175 F		175 F	
DISTANCE FROM LAKE OR STREAM	N/A		N/A	
DISTANCE FROM OCCUPIED BUILDING	15 F		35 F	
DISTANCE FROM PROPERTY LINE			+20 F	
DISTANCE FROM BOTTOM TO WATER TABLE			+ 4 F	

Owner: Name RUSSELL HENDRICKSON

Address RT 3 BOX 137

WERNANGA MN Zip No. 5646A

Permit No. SP 12-18,353-40
2 ft wide trench - 1 ft rock.

Signed by: 12-18,353-40

Zoning Administrator
Becker County, Minnesota

...the ... of ...

...the ... of ...

...the ... of ...

...the ... of ...

...the ... of ...

...the ... of ...

...the ... of ...

...the ... of ...

...the ... of ...

BECKER COUNTY

Building Permit No. _____ Sewage System Permit No. 12-1835340

Township RUNEBERG Sec. 20 Description T 138
R 36 - S 1/2 of NE 1/4 SE 1/4 NE 1/4 of SW 1/4

Work Authorized SEWER SYSTEM

Contractor LAKE

TYPE OF IMPROVEMENT:

() New Building () Alteration

Other _____

RESIDENTIAL PROPOSED USE:

☒ One Family Dwelling

() Multiple Dwelling _____ Units

NON-RESIDENTIAL PROPOSED USE:

Specify: _____

Size: _____


Stories _____ Basement () Yes () No Bedrooms 4 Bathrooms 1 1/2

Issued to: Name RUSSELL HENDRICKSON Ph. No 564-4268

Address: R 2 - Box 137 Town MENAGHA

State MN Zip 56464 Fire Number _____

Sketch



HORIZONTAL DISTANCE IN FEET
FROM NEW CONSTRUCTION TO:

High Water Mark of Lake _____

Side Lot Lines _____

Center Line of Public Road _____

Well Depth _____ Other _____

APPROVED: Board of Adjustment Date: _____

Planning Commission Date: _____

County Commissioners Date: _____

SEWAGE DISPOSAL SYSTEM DATA

Installed in 19 89 Septic Tank Drain Field

Capacity 1250 Gls. 500 Sq. Ft.

Distance from nearest well 75 Ft. 75 Ft.

Distance from lake or stream N/A Ft. N/A Ft.

Distance from occupied building 70 Ft. 20 Ft.

Distance from property line 40 Ft. 10 Ft.

Distance from bottom to Water Table _____ Ft. 4 Ft.

Lift Pump () Yes (L) No

1 Inch = _____ Feet

AGREEMENT: I HEREBY CERTIFY THAT THE INFORMATION CONTAINED HEREIN IS CORRECT AND AGREE TO DO THE PROPOSED WORK IN ACCORDANCE WITH THE DESCRIPTION ABOVE AND ACCORDING TO THE PROVISIONS OF THE ORDINANCE OF BECKER COUNTY. I AGREE TO POST THIS PERMIT ON THE PREMISES ON WHICH THE WORK IS TO BE DONE, AND MAINTAINED THERE UNTIL COMPLETION OF THE WORK. I AGREE THAT ANY VIOLATION OF THIS PERMIT OR THE BECKER COUNTY ZONING IS A MISDEMEANOR AND UPON CONVICTION THEREOF SHALL BE PUNISHED BY A FINE NOT TO EXCEED \$700.00 FOR EACH VIOLATION. NOTIFY THE BECKER COUNTY ZONING ADMINISTRATOR (847-4427) BEFORE BUILDING FOOTINGS HAVE BEEN COMPLETED. NO PART OF THE SEWAGE SYSTEM SHALL BE COVERED UNTIL IT HAS BEEN INSPECTED AND APPROVED. NOTIFY THE ZONING ADMINISTRATOR 24 HOURS BEFORE THE JOB IS READY FOR INSPECTION.

SIGNATURE OF OWNER

Received By M. K. Kuehne

Date 11-22-89

Approved By G. D. Swinby, Jr.
Becker County Zoning Administrator

BECKER COUNTY
DETROIT LAKES, MN 56501

LEGAL DESCRIPTION AND LOCATION	S 1/2 of NE 1/4, SE 1/4, NE 1/4 of SW 1/4						FIRE NUMBER
	Q S 1/2 of S 4 1/4						
	N/A	N/A	N/A	20	138	36	RUNEBERG
	Lake No.	Lake Name	Lake Classif.	Sec.	TWP	Range	TWP Name

IDENTIFICATION: Please Print All Information

Owner	Last Name	First	Initial	Mailing Address- No. Street, City and State			Zip No.	Tel. No.
	HENDRICKSON, RUSSELL			Rt 3 - Box 137				564-4268
Contractor	Name			MENAGERA MN.			56464	
	John Lake							

TYPE OF IMPROVEMENT:	RESIDENTIAL PROPOSED USE:		NON-RESIDENTIAL PROPOSED USE:
	☒ One Family Dwelling		Specify: _____
	☐ Multiple Dwelling _____ Units		Size: _____
☐ New Building		☐ Alteration	
Other _____			

ESTIMATED COST OF IMPROVEMENT \$		Construction Starting Date: _____	
PRINCIPAL TYPE OF FRAME & BUILDING	TYPE OF SEWAGE DISPOSAL:	DIMENSIONS:	
☐ Masonry	☐ Public	Basement: ☒ Yes ☐ No	
☐ Wood Frame	☒ Individual Septic Tank, etc.	Stories above basement: _____	
☐ Structural Steel	WATER SUPPLY:	Sq. feet (outside dimension) _____	
☐ Other - Specify _____	☐ Public ☒ Individual Well	Bedrooms _____ Baths <u>1 1/2</u>	
Year _____	Type _____ Depth _____	HEATING:	
☐ Cottage	MECHANICAL EQUIPMENT:	☐ Electric ☐ Gas ☐ Oil	
☐ Septic System	Elevator: ☐ Yes ☐ No	☐ Coal ☐ None	
Type of Roof: _____	Air Conditioning: ☐ Yes ☐ No	Other: <u>Bed</u>	
☐ Other _____	☐ Central ☐ Unit		

SEWAGE DISPOSAL SYSTEM DATA:	SEPTIC TANK	SEEPAGE PIT	DRAIN FIELD
Capacity	12.50 Gls.	500 Sq. Ft.	Sq. Ft.
Distance from nearest well	+75 Ft.	+75 Ft.	Ft.
Distance from lake or stream	N/A Ft.	N/A Ft.	Ft.
Distance from occupied building	+10 Ft.	+10 Ft.	Ft.
Distance from property line	+10 Ft.	+10 Ft.	Ft.
Distance from bottom to Water Table	Ft.	+4 Ft.	Ft.

All distances are shortest distance between nearest points

CHARACTERISTICS:

Lot Area is 440.25 square feet. Water frontage is N/A feet.
Building set back from high water mark is N/A feet. (Building Line)
Land height above high water mark at building line is +6 feet.
Building setback from ☒ State ☐ County ☐ Township Highway 85 feet from the ☐ Center Line ☒ Right of Way
Side yard is +10 and +10 feet. Rear yard is _____ feet.
Building will be located +10 feet from septic tank (Sewage System Permit must be obtained before installation).
Building will be located +10 feet from soil absorption system (Cesspool, Drainfield, etc.).

Agreement: I hereby certify that the information contained herein is correct and agree to do the proposed work in accordance with the description above set forth and according to the provisions of the ordinances of Becker County, Minnesota. I further agree that any plans and specifications submitted herewith shall become a part of this permit application. I also understand that this permit is valid for a period of six (6) months. Applicant further agrees that no part of the sewage system shall be covered until it has been inspected and accepted. It shall be the responsibility of the applicant for the permit to notify the County Zoning Administrator 48 hours before the job is ready for inspection.

Dated 11-21-89

Marie Hendrickson
Signature of Owner

When signed and approved by the Zoning Administration this becomes your permit. Permission is hereby granted to the above named applicant to perform the work described in the above statement and/or as shown on the sketch. This permit is granted upon the express condition that the person to whom it is granted, and his agent, employees and workmen shall conform in all respects to the ordinances of Becker County, Minnesota. This permit may be revoked at any time upon violation of said ordinances.

Dated _____

Flayel Svenby
Becker County Zoning Administrator
Cormorant Surcharge \$ _____

Permit Fee \$ 30.00 State Surcharge \$ 50

Comments: _____

INSPECTOR'S CHECK LIST
Make all measurements and computations

	ACTUAL IS ↓	MINIMUM Shall Be ↓	Sq. Ft.
Building Set Back from High Water Mark	Ft.	Ft.	
Building Set Back from State Highway	Ft.	Ft.	
Side Yard	& Ft.	& Ft.	
Rear Yard	Ft.	Ft.	
Elevation at Building Line above High Water Mark	Ft.	Ft.	

SEWAGE DISPOSAL SYSTEM STATISTICS


CATEGORY	SEPTIC TANK				SEEPAGE PIT				DRAIN FIELD			
	Actual		Should be		Actual		Should be		Actual		Should be	
Capacity <i>Block - Round</i>	<i>1000</i>	Gls.		Gls.		S F		S F	<i>500</i>	S F		S F
Distance from Nearest Well	<i>175</i>	F		F		F	<i>75</i>	F	<i>175</i>	F	<i>50</i>	F
Distance from Lake or Stream	<i>—</i>	F		F		F		F	<i>—</i>	F		F
Distance from Occupied Building	<i>15</i>	F	<i>10</i>	F		F	<i>20</i>	F	<i>35</i>	F	<i>20</i>	F
Distance from Property Line	<i>—</i>	F	<i>10</i>	F		F	<i>10</i>	F	<i>+ 50</i>	F	<i>10</i>	F
Distance from Bottom to Water Table	<i>—</i>	F	<i>—</i>	F		F	<i>4</i>	F	<i>+ 4</i>	F	<i>4</i>	F

Inspector's Comments: *trench 2 feet wide - 1 foot of Rock. Round Block tank - Rock supplied by owner, not the best, too small, not very clean. Workmanship okay, location and rock not that great.*

LAKE'S CONSTRUCTION & RETAIL
P. O. BOX 301
SEBEKA, MN 56477

OF ABBREVIATIONS
Gls — Gallons
SF — Square Feet
F — Linear Feet

North
←



[Signature]
Inspector's Signature

[Signature]
Title

Inspection
Dated *12-1-* 19 *85*
10:50 A.M.

Becker County
Agency