



08100000-2024



Becker County Planning & Zoning
915 Lake Ave
Detroit Lakes, MN 56501
(218) 846-7314
www.co.becker.mn.us

Septic Permit

Permit #: SS2019-11

Owner & Property Information

Owner Name:	STEVEN & JANE CARLSON	Parcel #:	081000000
Mailing Address:	STEVEN & JANE CARLSON 1670 NEWMAN DR IDAHO FALLS ID 83402	Secondary Parcel #:	
Phone #:	208-589-0479	Site Address:	20300 CO RD 131
Lake/River(1000/300):	Yes	Township - Sec/Twp/Rng:	DETROIT - 10/139/041
Lake/River Name:	Floyd (south bay) (Detroit) [GD]	Legal Description:	FLOYD LAKE POINT LOT 26
Pond/Wetland(50):	No	Designer:	Tom Falk's Backhoe Service Inc, L622 (Thomas Falk)
		Installer:	Tom Falk's Backhoe Service Inc, L622 (Thomas Falk)

Specifications

Tank to be Installed:	Holding Tank	Type of Drainfield:	
Total # Tanks Installed:	2	Full Size of Drainfield:	
System Status:	No Existing System	Reduced/Warrantied Size:	
System Serves:	Dwelling	Absorbion Area Size:	
Number of Bedrooms:	2	Rock Depth:	
Design Flow/GPD:	450	Chamber Type and Number:	
Garbage Disposal?	No	Chamber Trench SqFt/Chamber:	
Size of Lift Pump:		Is System Pressurized?	
Size of Lift Line:		Alarm?	Yes
Soil Sizing Factor:		Type of Alarm:	Float

Setbacks

Road Type:	County	Right of Way Marked:	Yes
Tank Dist to Road:	20 feet	Drainfield Dist to Road:	
Tank Dist to Closest Prop Line:	10 feet	Drainfield Dist to Closest Prop Line:	10 feet
Tank Dist to Nearest Structure:	10 feet	Drainfield Dist to Nearest Structure:	
Tank Dist to Well:	100 feet	Drainfield Dist to Well:	
Tank Dist to OHW:	130 feet	Drainfield Dist to OHW:	
Tank Dist to Pond/Wetland:		Drainfield Dist to Pond/Wetland:	
Tank Dist to Pressure Line:	10 feet	Drainfield Dist to Pressure Line:	

Other Information

Date Approved:	05/06/2019	Notes:	
Permit Fee:	\$150.00	Zoning Office Signature:	
Receipt Number:			
Date Paid:			

PERMIT MUST BE POSTED AT JOB SITE!

**** Please schedule for inspection prior to installation! ****
PERMIT EXPIRES ONE YEAR FROM DATE PAID!